

SOFTWARE HOUSE

From Tyco Security Products

C•CURE 9000 V2.9 and LifeSafety Power Integration Version 8.9.6.29

C•CURE 9000 v2.9 and Integration with LifeSafety Power Version 8.9.6.29 Release Notes

August 2021

This Release Note file provides important information for the C•CURE 9000 v2.9 LifeSafety Power Integration on both server and client machines. (In case of discrepancy, the information in this document supersedes the information in any document referenced herein.)

NOTE: This release supports C•CURE 9000 v2.9

Please read this file before installing the product.

Contents

1. [Feature](#)
2. [Contents of Installation](#)
3. [Requirements](#)
4. [Qualified Operating Systems](#)
5. [Limitations](#)
6. [Installation](#)
7. [Features](#)

1. Overview

The C•CURE 9000 LifeSafety Power Integration is a product that integrates LifeSafety Power NetLink communication modules with the C•CURE 9000 Security Management System.

The LifeSafety Power NetLink module allows power systems manufactured by LifeSafety Power to be accessed over a network through SNMP or HTTP protocols. NetLink allows the advanced capabilities to a power system such as remote monitoring of power system status, remote battery testing, scheduled service due, enclosure or room temperature out of range, impending lock failure, and other remote servicing features. Through the LifeSafety Power C•CURE 9000 integration, this information is transferred automatically to C•CURE 9000, allowing events to be triggered on any NetLink event.

Background

Integration with C•CURE 9000 allows users to centrally manage LifeSafety Power products in the field through the C•CURE interface, providing monitoring of the NetLink modules, power supplies, and M8 managed lock control modules.

Benefits

- Remote Servicing - Reduce servicing costs through remote servicing features such as remote power cycle and remote troubleshooting.
- Remote battery testing - Manual or scheduled remote battery testing eliminates the need for an on-site technician.
- Reduced downtime - Alerts for insufficient battery backup time, impending lock failure, lock end of life, and out of range environmental conditions.

- Complete integration allows full control of the power system through the C•CURE 9000 interface, eliminating the need for accessing multiple interfaces.

2. Contents of Installation

The installation contains the following files:

- CCURE_LSP_IM.exe – *Installation program for the LifeSafety Power Integration*
- LSP_Integration_UserGuide.pdf – *C•CURE 9000 Version 2.9 LifeSafety Power Integration Guide*
- LSP_Integration_ReleaseNotes.pdf – *C•CURE 9000 v2.9 Integration with LifeSafety Power Integration Version 8.9.6.29 Release Notes*

3. Requirements

The C•CURE 9000 LSP Integration product requires the following software versions:

- C•CURE 9000 v2.9 SP2 CU01
- C•CURE 9000 LSP Integration v8.9.6.29
- MS Framework 4.8
- Supported NL4 version: 9.56.85
- Supported NLX version: 0.46.85
- Supported power supply models: FPO75, FPO150, FPO250, FPV4, FPV6, FPV102, FPV104
- Supported M8 controller version: 0.50

4. Qualified Operating Systems

The LSP Integration supports Windows 8/8.1/10/Windows 2012 R2/Windows 2016/Windows 2019. The LSP Integration supports C•CURE MAS and SAS server installation.

5. Limitations

The LSP Integration product has the following limitations:

- English only

The LSP Integration product has the following capacity limitations:

- 750-LSP NetLinks
- 5000-LSP Connected Hardware

The LSP Integration product has the following functional limitations:

- Due to the number of fields to be saved with NL-X devices, opening, saving, and closing NL objects in C•CURE may cause the client to appear frozen momentarily, depending on system specification and available resources.
- When enabling DHCP or changing IP address on NetLink website system must be rebooted immediately, otherwise the C•CURE LSP integration won't establish connection automatically. C•CURE LSP will attempt to re-establish connection within 2 minutes.

The supported performance of this integration is for a total system transaction volume of less than 20 transactions per second including LSP events and all other events on the C•CURE Server.

Installation

See the *C•CURE 9000 v2.9 / LifeSafety Power Integration Guide*.

6. Features

This LifeSafety Power integration now has the following features and enhancements:

- Enrolling devices capability: NetLink, Power Supplies, M8 Controllers, NAC devices, M8 outputs
- Real-life NetLink devices monitoring
- NetLink objects management capability.
- NetLink to C•CURE alerts mapping capability.
- NetLink configuration maintenance
- Property based C•CURE events triggering capability
- Sending LSP commands over C•CURE executors
- Netlink Objects C•CURE map integration
- Diagnostic Feature
- Journal messaging
- C•CURE MAS/SAS support – see *LSP Integration Guide* for details
- Supports IPV6 connection to NetLinks

7. Command List

This integration supports a number of commands for each device including:

Netlink	M8 controller	M8 Output	Power Supply
Reboot System Enable All Outputs Disable All Outputs Reset All Outputs	Enable All M8 Outputs Disable All M8 Outputs Reset All M8 Outputs	Enable Output Disable Output Reset Output	Start Battery Test Stop Battery Test Reset AC and System Fault Counters

Please note, list is subject to change. For a complete list please refer to C•CURE 9000 v2.9/ LifeSafety Power Integration Guide.

8. Event List

This integration supports a number of event types for each device including:

NetLink supported event types:

ADC1 Under Low Limit
ADC2 Under Low Limit
Connection Status
Event1
External Temperature Beyond Limit
Hall Sensor1 Current Exceeds Upper Limit

Hall Sensor1 Current Under Low Limit
Hall Sensor2 Current Exceeds Upper Limit
Hall Sensor2 Current Under Low Limit
Service Due
System Fault Status

M8 Output event types:

Current Exceeds Upper Limit
Current Under Lower Limit
FAI Status
Power Ready
Voltage Exceeds Upper Limit
Voltage Under Lower Limit

Power Supply event types:

AC Fault Status
Battery End of Life Reached
Battery Charging Current
Battery Condition Low
Battery Test Completed
FAI Status
Output Voltage
System Fault Status
Battery Backup Time Failed

Please note, list is subject to change, for a complete list please refer to C•CURE 9000 v2.9/LifeSafety Power Integration Guide.

End of Release Notes

The trademarks, logos, and service marks displayed on this document are registered in the United States [or other countries]. Any misuse of the trademarks is strictly prohibited and Tyco will aggressively enforce its intellectual property rights to the fullest extent of the law, including pursuit of criminal prosecution wherever necessary. All trademarks not owned by Tyco are the property of their respective owners, and are used with permission or allowed under applicable laws.

Product offerings and specifications are subject to change without notice. Actual products may vary from photos. Not all products include all features. Availability varies by region; contact your sales representative.

© 2021 Tyco Security Products.

All Rights Reserved.